SUGGESTED I	MAINTENANCE SCHEDULE			
Sub-system or component	Maintenance Action 1)	Frequency 2)	Remarks	Check
General Observations	Check that the inverter is working, and without fault lights The inverter will record the daily kWh production; this should on average correspond with the daily values for the same period in the CEC yield table supplied.	Ongoing		
Site	Verify:  (a) Cleanliness (accumulation of debris around and/or under array).  (b) No shading of array.	Ongoing, Max Quarterly	Clean site as requested.  Trim trees, if required.	
PV Modules	Verify cleanliness (accumulation of dust or fungus on array).  Check for visual defects including;  (a) fractures (b) browning (c) moisture penetration (d) frame corrosion  Inspect junction boxes for;	1 year	Clean if necessary  Modules with visual defects should be further inspected for performance and safety to determine the need for replacement.	
	<ul> <li>(a) tightness of connections</li> <li>(b) water accumulation/build up</li> <li>(c) integrity of lid seals</li> <li>(d) integrity of cable entrances, glands and or conduit sealing</li> <li>(e) integrity of clamping devices</li> <li>Verify bypass diodes</li> </ul>		Any defective seals, clamps and bypass diodes should be replaced.	
	Verify mechanical integrity of conduits.  Verify insulation integrity of cables installed without conduit.	- 5 years	Any damaged conduits should be replaced  Any damaged cable should be replaced	
Wiring installations	Check junction boxes for;  (a) tightness of connection (b) high resistance (hot) connections (c) water accumulation/build up (d) integrity of lid seals (e) integrity of cable entrance, glands and/or conduits seals. (f) Integrity of clamping devices.  Verify; (i) blocking diodes (ii) surge arresters for degradation  Check earthing connections for; (a) tightness of connections (b) corrosion (c) measure earth continuity	1 year	Replace or repair earthing system	
Electrical Characteristics	Measure open circuit voltage Voc  Measure short circuit current Isc  Measure "power curve" and compare to STC values.		According to AS 5033 clause 8.2	
Protective Devices	Verify integrity of fuses.  Verify and measure operation of CB's and RCD's.  Verify operation of earth fault protection system.  Verify operation of solar array isolation devices.			
Mounting System	Verify tightness and integrity of bolts and other fastening devices  Inspect for corrosion and reseal roof penetrations if required  Information to the expansion of the expansi		Replace or repair as necessary	

- 1) This list of items is not exhaustive but are examples only.
- 2) Values for frequency are examples. Frequencies may increase due to site or environmental conditions; corrosions checks
- should be performed during regular cleaning in locations close to salt water.

  3) Your System will have high AC and DC voltages. All electrical testing must be performed by a licensed and CEC Accredited Electrician.